



Date: 23-06-23

To,

DAV Public Schools

Darbhang Road, Bakhri,

Muzaffarpur (Bihar)

Testing & Commissioning Report

This is to certify that our work for Fire Hydrant Systems at DAV Public School, Darbhanga Raod, Bakhri, Muzaffarpur (Bihar) has successfully completed & all equipment's have been properly installed, tested and functional.

Name of Work: Supply, Installation, Testing & Commissioning of Fire Hydrant Systems.

Work Order No.: As per our Quot. Ref. No. KSTAR/030/23-24 dated 02-06-23.

Thanking you,

For KSTAR

A handwritten signature in blue ink is written over a yellow rectangular background. To the right of the signature is a circular blue stamp with 'KSTAR' written twice inside.

Authorised Signatory



Date: 05-07-2023

To,
DAV Public School
Darbhanga Road, Bakhri,
Muzaffarpur (Bihar).

Validity: 05-07-2023 to 04-07-2024

Certificate

This is to certify that the 69 nos. of ABC Powder type Fire Extinguishers (Stored Pressure) having Capacity – 6 Kg MAP (Mono Ammonium Phosphate) with Nitro Oxide & 4 nos. of CO₂ Type Fire Extinguishers confirming to IS: 15683 have done successfully Hyd. Tested at 35kgf/Cm² & 250 Kgf/Cm² subsequently.

This certificate extends the warranty for a period of One year. This warranty covers the repair of replacement of the Fire Extinguishers & does not cover if tampered or used.

Thanking you,

For KSTAR

Authorised Signatory